



**2015 ANNUAL DRINKING WATER QUALITY REPORT**  
**TOWN OF MOUNT GILEAD**  
Water System Number: **03-62-015**  
**MONTGOMERY COUNTY PUBLIC UTILITIES**  
Water System Number: **03-62-010**



We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your source(s) of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and reliable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies.

**If you have any questions about this report or concerning your water, please contact Chris Hildreth, Public Utilities Director, or Kenneth Black, WTP ORC with Montgomery County Public Utilities at (910) 439-6197. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings held every third Tuesday of each month at the County Administration Building, located at 102 Spring Street, Troy, (910) 576-4221.**

**Mount Gilead Customers (customers of purchase systems) may contact the town directly regarding information in this report: Town of Mount Gilead System ID#: 03-62-015 Daniel Medley, Public Works Director, 910-439-5111.**

**You can find direct test result information online at The North Carolina Department of Environmental Quality <http://deq.nc.gov/> Research: Data: Public Water Supply: Drinking Water Watch: or <https://www.pwss.enr.state.nc.us/NCDWW2/> The Town of Mount Gilead also has this report online at [www.mtgileadnc.com](http://www.mtgileadnc.com)**

## **WHAT EPA WANTS YOU TO KNOW**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Name of Utility] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban

stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

## **WHEN YOU TURN ON YOUR TAP, CONSIDER THE SOURCE**

The water that is used by this system is surface water from Lake Tillery, part of the Yadkin-Pee Dee basin. The water is treated at the facility located at 724 Hydro Road, Mt. Gilead, NC and pumped into the Montgomery County transmission system where it is sold to over 5300 individually metered customers, all five towns in the County, Carolina Water Service for Woodrun on Tillery and Carolina Forest subdivisions, and the Town of Robbins in Moore County.

## **SOURCE WATER ASSESSMENT PROGRAM (SWAP) RESULTS**

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Montgomery County Water System was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

### **Susceptibility of Sources to Potential Contaminant Sources (PCSs)**

<b>Source Name</b>	<b>Susceptibility Rating</b>	<b>SWAP Report Date</b>
Lake Tillery	Moderate	July 2015

The complete SWAP Assessment report for [SYSTEM NAME] may be viewed on the Web at: [www.ncwater.org/pws/swap](http://www.ncwater.org/pws/swap). Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to [swap@ncdenr.gov](mailto:swap@ncdenr.gov). Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the system’s potential to become contaminated by PCSs in the assessment area.

## **HELP PROTECT YOUR SOURCE WATER**

Protection of drinking water is everyone’s responsibility. You can help protect your community’s drinking water source(s) in several ways: (examples: dispose of chemicals properly; take used motor oil to a recycling center, volunteer in your community to participate in group efforts to protect your source, etc.).

## **VIOLATIONS THAT YOUR WATER SYSTEM RECEIVED FOR THE REPORT YEAR**

During the year 2015, or any compliance period that ended in 2015, we are pleased to report that this system received no violations.



## WATER QUALITY DATA TABLES OF DETECTED CONTAMINANTS

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The tables below list all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, (2015).** The EPA and the State allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

### **Important Drinking Water Definitions:**

***Not-Applicable (N/A)*** – Information not applicable/not required for that particular water system or for that particular rule.

***Non-Detects (ND)*** - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.

***Parts per million (ppm) or Milligrams per liter (mg/L)*** - One part per million corresponds to one minute in two years or a single penny in \$10,000.

***Parts per billion (ppb) or Micrograms per liter (ug/L)*** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

***Parts per trillion (ppt) or Nanograms per liter (nanograms/L)*** - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

***Parts per quadrillion (ppq) or Picograms per liter (picograms/L)*** - One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

***Picocuries per liter (pCi/L)*** - Picocuries per liter is a measure of the radioactivity in water.

***Million Fibers per Liter (MFL)*** - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

***Nephelometric Turbidity Unit (NTU)*** - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

***Action Level (AL)*** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

***Treatment Technique (TT)*** - A required process intended to reduce the level of a contaminant in drinking water.

***Maximum Residual Disinfection Level (MRDL)*** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

***Maximum Residual Disinfection Level Goal (MRDLG)*** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

***Maximum Contaminant Level (MCL)*** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

***Maximum Contaminant Level Goal (MCLG)*** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

***Locational Running Annual Average (LRAA)*** – The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.

## TABLES OF DETECTED CONTAMINANTS

### Microbiological Contaminants in the Distribution System – (Mount Gilead)

Contaminant (units)	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	N	0	0	1 positive sample / month* Note: If either an original routine sample and/or its repeat samples(s) are fecal coliform or <i>E. coli</i> positive, a Tier 1 violation exists.	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (presence or absence)	N	0	0		Human and animal fecal waste

\* If a system collecting fewer than 40 samples per month has two or more positive samples in one month, the system has a MCL violation.

### Turbidity\* (Montgomery County)

Contaminant (units)	Treatment Technique (TT) Violation Y/N	Your Water	MCLG	Treatment Technique (TT) Violation if:	Likely Source of Contamination
Turbidity (NTU) - Highest single turbidity measurement	N	.28 NTU	N/A	Turbidity > 1 NTU	Soil runoff
Turbidity (NTU) - Lowest monthly percentage (%) of samples meeting turbidity limits	N	99.95 %	N/A	Less than 95% of monthly turbidity measurements are ≤ 0.3 NTU	

\* Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The turbidity rule requires that 95% or more of the monthly samples must be less than or equal to 0.3 NTU.

### Inorganic Contaminants (Montgomery County)

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low – High	MCLG	MCL	Likely Source of Contamination
Arsenic (ppb)	5-12-15	N	ND	N/A	0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Fluoride (ppm)	5-12-15	N	ND	N/A	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

### Nitrate/Nitrite Contaminants (Montgomery County)

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low – High	MCLG	MCL	Likely Source of Contamination
Nitrate (as Nitrogen) (ppm)	3-10-15	N	ND	N/A	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (as Nitrogen) (ppm)	3-10-15	N	ND	N/A	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

### Asbestos Contaminant (Montgomery County)

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low – High	MCLG	MCL	Likely Source of Contamination
Total Asbestos (MFL)	10-9-13	N	ND	N/A	7	7	Decay of asbestos cement water mains; erosion of natural deposits

**Synthetic Organic Chemical (SOC) Contaminants Including Pesticides and Herbicides (Montgomery County)**

Contaminant (units)	Sample Dates	MCL Violation Y/N	Your Water	Range Low – High	MCLG	MCL	Likely Source of Contamination
Atrazine (ppb)	7-7-15 10-12-15	N	0.018 0.120	0.018 - 0.120	3	3	Runoff from herbicide used on row crops

**Lead and Copper Contaminants (Montgomery County Numbers Top; Mount Gilead Numbers Lower Rows)**

MONTGOMERY COUNTY						
Contaminant (units)	Sample Date	Your Water	Number of sites found above the AL	MCLG	AL	Likely Source of Contamination
Copper (ppm) (90 <sup>th</sup> percentile)	June-Sept 2015	0.219	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 <sup>th</sup> percentile)	June-Sept 2015	.0035	1	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
MOUNT GILEAD						
Contaminant (units)	Sample Date	Your Water	Number of sites found above the AL	MCLG	AL	Likely Source of Contamination
Copper (ppm) (90 <sup>th</sup> percentile)	June-Sept 2015	0.133	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 <sup>th</sup> percentile)	June-Sept 2015	N/D	0	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

**Radiological Contaminants (Montgomery County)**

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low – High	MCLG	MCL	Likely Source of Contamination
Uranium (pCi/L)	10-2-12	N	ND	N/A	0	20.1	Erosion of natural deposits

\* Note: The MCL for beta/photon emitters is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles.

**Total Organic Carbon (TOC) (Montgomery County)**

Contaminant (units)	TT Violation Y/N	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low – High	MCLG	TT	Likely Source of Contamination	Compliance Method (Step 1 or ACC#_)
Total Organic Carbon (removal ratio) (TOC)-TREATED	N	1.44	1.32 - 1.65	N/A	TT	Naturally present in the environment	Step 1

**Disinfectant Residuals Summary (Mount Gilead)**

Disinfectant (units)	Year Sampled	MRDL Violation Y/N	Your Water (highest RAA)	Range Low – High	MRDLG	MRDL	Likely Source of Contamination
Chlorine (ppm)	2015	N	0.82	0.25 - 2.00	4	4.0	Water additive used to control microbes

**Stage 2 Disinfection Byproduct Compliance - Based upon Locational Running Annual Average (LRAA)**

(Montgomery County Numbers Top Rows; Mount Gilead numbers lower section)

MONTGOMERY COUNTY							
Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range Low – High	MCLG	MCL	Likely Source of Contamination
TTHM (ppb)							Byproduct of drinking water disinfection
B01	2015	N	57	30 - 37	N/A	80	
B02	2015	N	51	56 - 74	N/A	80	
B03	2015	N	58	45 - 78	N/A	80	
B04	2015	N	49	52 - 62	N/A	80	
HAA5 (ppb)							Byproduct of drinking water disinfection
B01	2015	N	47	27 - 35	N/A	60	
B02	2015	N	50	58 - 84	N/A	60	
B03	2015	N	50	38 - 51	N/A	60	
B04	2015	N	37	28 - 52	N/A	60	
MOUNT GILEAD							
Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range Low – High	MCLG	MCL	Likely Source of Contamination
TTHM (ppb)							Byproduct of drinking water disinfection
B01	2015	N	45	N/A	N/A	80	
B02	2015	N	41	N/A	N/A	80	
HAA5 (ppb)							Byproduct of drinking water disinfection
B01	2015	N	29	N/A	N/A	60	
B02	2015	N	36	N/A	N/A	60	

The PWS Section requires monitoring for other misc. contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic effects or aesthetic effects (such as taste, odor, and/or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.

**Other Miscellaneous Water Characteristics Contaminants (Montgomery County)**

Contaminant (units)	Sample Date	Your Water	Range Low – High	SMCL
Iron (ppm)	05-12-15	ND	N/A	0.3
Manganese (ppm)	05-12-15	ND	N/A	0.05
Sodium (ppm)	05-12-15	14.590	N/A	N/A
Sulfate (ppm)	05-12-15	23.200	N/A	250
pH	05-12-15	7.2	N/A	6.5 to 8.5